





## **GAS STICK PART NUMBER MATRIX** G2 A - 04 04 C - 1 - 0 0 **Gas Stick** Outlet Filter Option (0.003 µM) G2 = Regulator & Gauge w/ Mini Ball Valve 0 = Not Required G3 = Regulator & Gauge Only 1 = TEM Filter (low flow) 2 = TEM Filter (high flow) 3 = Entegris Filter Regulator Size \* A = 0.15 CvB = 1.8 Cv**Lockout and Mounting Bracket Options** 0 = Not Required Inlet Size \*\* 1 = Mounting Bracket (Strut Channel Compatible) 04 = 1/4" 2 = Valve Lockout 06 = 3/8" 3 = Valve Lockout and Mounting Bracket 08 = 1/2" 12 = 3/4" Gauge 1 = -30inHg-160 psig **Outlet Size Connection Type** 04 = 1/4" C = Compression in, Compression out 06 = 3/8" T=Tube in, Compression out 08 = 1/2" 12 = 3/4" \* 0.15 Cv size is typically used for 1/4" gas sticks, while 1.8 Cv is typically used on 3/8" & 1/2" gas sticks. $^{\star\star}$ For G3 configurations, inlet size is only offered in 1/4" and 1/2".

L